



August 19, 2014

COUNTY MATERIALS CORPORATION
MARK KWARCANY
P.O. BOX 100
MARATHON WI 54448

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: COUNTY MATERIALS CORPORATION
Product Name: SEPTIC, HOLDING OR PUMP
Model Number(s): 1250
(43.5 IN. L.L., 28.4 GAL/IN., 72 IN. MAX. DEPTH OF BURY, 592 G.P.D. WHEN USED
AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER; TANK DIMENSIONS (OD) = 97 IN. L X 84 IN. W X 61.5 IN. H)
Product File No: 20140202

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of August 2019.**

This approval supersedes the approval issued on 6/19/2009 under product file number 20090232.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank's cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- This product is approved to use the following:
 - Two inch schedule 40 PVC cast in riser for electrical wiring.
 - Pipe materials constructed in conformance with Table 384.30-2 or 384.30-11, Wis. Admin. Code poured into tank cover or access cover.
 - Cast-A-Seal by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc.
 - Dual inlets with one access opening above both inlets.
 - Dual inlets with one access opening above each inlet.
 - Inlet(s) and outlet(s) on opposite sides of tank, inlet(s) on end or side of tank with outlet on end of tank or interior wall.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - E-Z Set Lids and Risers installed in accordance with the E-Z Set Tank Company, Inc product approval issued by this department or cast into the concrete cover.

COUNTY MATERIALS CORPORATION

Page 2

August 19, 2014

Product File No: 20140202

- When this product is installed as a septic tank, the minimum distance between the inlet(s) and outlet(s) must be at least equal to the length of the longest wall or the diameter of a circle that has the same surface area of the tank, whichever is less.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.
POWTS Product Reviewer
phone: (608) 267-5265
fax: (608) 267-9723
email: glen.jones@wi.gov